

Display energy certificate (DEC)



Steeple Morden School
Steeple Morden School
7 Hay Street
Steeple Morden
ROYSTON
SG8 0PD

Operational rating

D

Certificate number: 3834-2610-2502-8324-9006

Valid until: 27 May 2023

Total useful floor area: 1112 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D	77 D	
101-125	E		100
126-150	F		
150+	G		

Previous operational ratings

Date	Operational rating
May 2022	77 D
May 2021	70 C
May 2020	104 E

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
May 2022	23	19	0
May 2021	19	19	0
May 2020	33	23	0

Assessment details

Assessor's name: Mr Richard Holmes

Employer/Trading name: Third Stone Limited

Employer/Trading address: 10 Denton Drive, West Bridgford. Nottingham. NG2 7FS

Assessor's declaration: Not related to the occupier.

Accreditation scheme: Elmhurst Energy Systems Ltd

Issue date: 7 September 2022

Nominated date: 28 May 2022

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	38.24	63.09
Typical energy use (kWh/m ² /year)	40	138.76
Energy from renewables	0%	0%